


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006040
DATE: 06/03/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Fiberglass Sliding Patio Door" Configuration: OX/XO Glazing-IG-1/8"TempGL/FER Frame: W-5'11" H-8'0" Panel: W-3'0" H-7'8" STP: 4320 Pa (+90.2/-90.2 psf)

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWWDA 101/I.S.2-97 ANSI/AAMA/WDMA 101/I.S.2/NAFS-02 AAMA/WDMA/CSA 101/I.S.2/A440-05	SD-R55 1810x2426 (71 x 96) FER-Type A Level 10-Passed

Product Tested By: Architectural Testing, Inc.
Report No: ATI-56688.01-122-47 (Structural/FER)
Expiration Date: **March 31, 2009**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**


11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006195A-R
DATE: 09/07/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Fiberglass Sliding Patio Door" Sliding Glass Door Configuration: XOO Glazing-CG-1/8"TempGL/FER Frame: W-2721mm(8'11") H-2426mm(8'0") Panel: W-902mm(3'0") H-2342mm(7'8") STP PSF: Pos+67.7 Neg-67.7

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWWDA 101/I.S.2-97 AAMA/WDMA 101/I.S.2/NAFS-02 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM F842	SD-R45 2721 x 2426 (107 x 96) FER-Passed

Product Tested By: Architectural Testing, Inc.
 Report No: 58600.01-801-47 (Structural/FER)
 Expiration Date: June 30, 2009

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**


11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006195R
DATE: 09/07/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Fiberglass Sliding Patio Door" Sliding Glass Door Configuration: XOO Glazing-CG-1/8"TempGL/FER Frame: W-2721mm(8'11") H-2426mm(8'0") Panel: W-902mm(3'0") H-2342mm(7'8") STP PSF: Pos+52.6 Neg-52.6

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWDA 101/I.S.2-97 AAMA/WDMA 101/I.S.2/NAFS-02 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM F842	SD-R35 2721 x 2426 (107 x 96) FER-Passed

Product Tested By: Architectural Testing, Inc.
 Report No: 58600.01-801-47 (Structural/FER)
 Expiration Date: **June 30, 2009**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**


11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006196B-R
DATE: 09/07/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Fiberglass Sliding Patio Door" Sliding Glass Door Configuration: OXXO Glazing-CG-1/8"TempGL/FER Frame: W-3556mm(11'8") H-2083mm(6'10") Panel: W-902mm(3'0") H-1999mm(6'6") STP PSF: Pos+75.2 Neg-75.2

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWWDA 101/I.S.2-97 AAMA/WDMA 101/I.S.2/NAFS-02 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM F842	SD-R45 3556 x 2083 (140 x 82) FER-Passed

Product Tested By: Architectural Testing, Inc.
 Report No: 58320.01-801-47 (Structural/FER)
 Expiration Date: **June 30, 2009**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**


11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006196R
DATE: 09/07/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Fiberglass Sliding Patio Door" Sliding Glass Door Configuration: OXXO Glazing-CG-1/8"TempGL/FER Frame: W-3556mm(11'8") H-2426mm(8'0") Panel: W-902mm(3'0") H-2342mm(7'8") STP PSF: Pos+52.6 Neg-52.6

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWWDA 101/I.S.2-97 AAMA/WDMA 101/I.S.2/NAFS-02 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM F842	SD-R35 3556 x 2426 (140 x 96) FER-Passed

Product Tested By: Architectural Testing, Inc.
 Report No: 58320.01-801-47 (Structural/FER)
 Expiration Date: **June 30, 2009**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659