


# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005261  
DATE: 11/10/03  
CERTIFICATION PROGRAM: Structural  
COMPANY: Therma-Tru  
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 108 Mutzfeld Road Butler, IN 46721	Series "SPD" Sliding Patio System Vinyl Sliding Glass Door XO/IG/SIG-1/8"TempGL/REIN/FER  <u>STP PSF</u> Frame: W-6'1" Panel: W-2'11" Pos+75.0 H: 6'10" H-6'5" Neg-75.0

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/I.S.2-97/ AAMA 1302.5-76	SGD-R50 FER-Passed (Design Pressure: +50/-50 psf)

Product Tested By: Certified Testing Laboratories  
Report No: CTLA-1092W-1 (Structural/FER)  
Expiration Date: April 30, 2007

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4655-104 Monticello Avenue  
Williamsburg, VA 23188  
TEL: (757) 258-8808  
FAX: (757) 258-8815