


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006041R
DATE: 06/03/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Slim-Line Sliding Patio Door" 4 Panel Continuous Head/Sill w/Transom Configuration: OXXO/OO Glazing-IG-1/8"TempGL/FER Frame: W-11'8" H-9'4" Transom W-11'8" H-1'4" Panel: W-2'11" H-7'8" STP PSF: Pos+30.0 Neg-30.0


SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWDA 101/I.S.2-97 AAMA 450-00 ASTM F842	SGD-R20/Mulled Fenestration Rating-R20/Applied Rating-R20 FER-Passed

Product Tested By: ETC Laboratories
Report No: ETC-04-741-15689.0 (Structural/FER) Certification Revised 06/14/05
Expiration Date: **April 30, 2008**
Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

**11870 Merchants Walk Suite 202
Newport News, VA 23606
TEL: (757) 594-8658
FAX: (757) 594-8659**

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006042R-1
DATE: 06/03/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.


COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Slim-Line Sliding Patio Door" 3 Panel Continuous Head/Sill w/Transom Configuration: OOX/O Glazing-IG-1/8"TempGL/FER Frame: W-8'11" H-8'0" Transom W-8'11" H-1'4" Panel: W-3'0" H-6'5" STP PSF: Pos+52.5 Neg-52.5

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWDA 101/I.S.2-97 AAMA 450-00 ASTM F842	SGD-R35/Mulled Fenestration Rating-R35/Applied Rating-R35 FER Passed

Product Tested By: ETC Laboratories
 Report No: ETC-04-741-15691.0 (Structural/FER) Certification Revised 11/03/05
 Expiration Date: April 30, 2008
 Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 11870 Merchants Walk Suite 202
 Newport News, VA 23606
 TEL: (757) 594-8658
 FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006043R-1
DATE: 06/03/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Slim-Line Sliding Patio Door" 3 Panel Continuous Head/Sill w/Transom Configuration: OOX/O Glazing-IG-1/8"TempGL/FER Frame: W-8'11" H-9'4" Transom W-8'11" H-1'4" Panel: W-3'0" H-7'8" STP PSF: Pos+52.5 Neg-52.5

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWDA 101/I.S.2-97 AAMA 450-00 ASTM F842	SGD-R35/Mulled Fenestration Rating-R35/Applied Rating-R35 FER-Passed

Product Tested By: ETC Laboratories
 Report No: ETC-04-741-15692.0 (Structural/FER/Certification Revised 11/03/05)
 Expiration Date: April 30, 2008
 Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**


11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006044R
DATE: 06/03/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Slim-Line Sliding Patio Door" 3 Panel Continuous Head/Sill w/Transom Configuration: OOX/OO Glazing-IG-1/8"TempGL/FER Frame: W-11'11" H-8'0" Transom W-6'0" H-1'4" Panel: W-4'0" H-6'5" STP PSF: Pos+45.0 Neg-45.0


SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWDA 101/L.S.2-97 AAMA 450-00 ASTM F842	SGD-R30/Mulled Fenestration Rating-R30/Applied Rating-R30 FER-Passed

Product Tested By: ETC Laboratories
 Report No: ETC-04-741-15693.0 (Structural/FER) Certification Revised 06/14/05
 Expiration Date: **April 30, 2008**
 Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202
 Newport News, VA 23606
 TEL: (757) 594-8658
 FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006045R
DATE: 06/03/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Slim-Line Sliding Patio Door" 3 Panel Continuous Head/Sill w/Transom Configuration: OOX/OO Glazing-IG-1/8"TempGL/FER Frame: W-11'11" H-9'4" Transom W-6'0" H-1'4" Panel: W-4'0" H-7'8" STP PSF: Pos+30.0 Neg-30.0


SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWWDA 101/L.S.2-97 AAMA 450-00 ASTM F842	SGD-R20/Mulled Fenestration Rating-R20/Applied Rating-R20 FER-Passed

Product Tested By: ETC Laboratories
 Report No: ETC-04-741-15694.0 (Structural/FER) Certification Revised 06/14/05
 Expiration Date: **April 30, 2008**
 Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.

11870 Merchants Walk Suite 202
 Newport News, VA 23606
 TEL: (757) 594-8658
 FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006048R
DATE: 06/03/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Slim-Line Sliding Patio Door" 4 Panel Continuous Head/Sill w/Transom Configuration: OXXO/OO Glazing-IG-1/8"TempGL/FER Frame: W-11'8" H-8'0" Transom W-11'8" H-1'4" Panel: W-3'0" H-6'5" STP PSF: Pos+45.0 Neg-45.0

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWWDA 101/I.S.2-97 AAMA 450-00 ASTM F842	SGD-R30/Mulled Fenestration Rating-R30/Applied Rating-R30 FER-Passed

Product Tested By: ETC Laboratories
 Report No: ETC-04-741-15695.0 (Structural/FER) Certification Revised 06/14/05
 Expiration Date: **April 30, 2008**
 Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.


11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006053R
DATE: 06/03/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Slim-Line Sliding Patio Door" Fixed Panel w/Transom Configuration: O/O Glazing-IG-1/8"TempGL/FER Frame: W-4'3" H-9'4" Transom W-4'3" H-1'4" Panel: W-4'0" H-7'8" STP PSF: Pos+45.0 Neg-45.0


SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWDA 101/I.S.2-97 AAMA 450-00 ASTM F842	SGD-R30/Mulled Fenestration Rating-R30/Applied Rating-R30 FER-Passed

Product Tested By: ETC Laboratories
 Report No: ETC-04-741-15910.0 (Structural/FER) Certification Revised 06/14/05
 Expiration Date: **January 31, 2009**
 Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202
 Newport News, VA 23606
 TEL: (757) 594-8658
 FAX: (757) 594-8659

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006058R
DATE: 06/03/05
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "Slim-Line Sliding Patio Door" Boxed Unit w/Transom Configuration: OXO/O Glazing-IG-1/8"TempGL/FER Frame: W-10'2" H-9'4" Transom: W-10'2" H-1'4" Panel: W-3'0" H-7'8" STP PSF: Pos+30.0 Neg-30.0

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWWDA 101/I.S.2-97 AAMA 450-00 ASTM F842	SGD-R20/Mulled Fenestration Rating-R20/Applied Rating-R20 FER-Passed

Product Tested By: Testing Evaluation Laboratories, Inc.
 Report No: 05-0419-1 (Structural/FER)/Certification Revised 06/14/05
 Expiration Date: **January 31, 2009**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659

