

R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197 Facsimile 813.754.9989

Florida Board of Professional Engineers Certificate of Authorization No. 9813

Product Evaluation Report

Report No.: FL 7730.3

Date: November 14, 2006

Product Category: Exterior Doors

Product sub-category: Swinging Exterior Door Assemblies

Product Name: "FiberClassic", "SmoothStar", "ClassicCraft"
Or "ClassicCraft Rustic" Series
Opaque Fiberglass Single Door with Sidelite
Inswing / Outswing


Manufacturer: Therma-Tru Corporation
118 Industrial Drive
Edgerton, OH 43517
Phone: 419-298-1740

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Wendell W. Haney, P.E. (System ID # 1993) for Therma-Tru Corporation based on Rule Chapter No. 9B-72.070, Method 1d of the State of Florida Product Approval, Department of Community Affairs-Florida Building Commission.

RW Building Consultants and Wendell W. Haney, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code (2004 Edition).

See Drawing No.: FL 3045 prepared by R W Building Consultants, Inc. and signed and sealed by Wendell W. Haney, P.E. (PE # 54158) for specific use parameters.



Wendell W. Haney, P.E.
PE # 54158
November 14, 2006


Limitations

1. The “Opaque Fiberglass Single Door with Sidelite” “Impact” has been evaluated and meets the requirements for use within the State of Florida including the “High Velocity Hurricane Zone”.
2. When used in the “HVHZ” this product complies with Section 1626 of the Florida Building Code and does not require an impact resistant covering.

3. Size Limitations:

<u>Configurations</u>	<u>MAX. Width</u>	<u>MAX. Height</u>
Single (Inswing) OX or XO	54.75”	82.25”
Single (Outswing) OX or XO	53.25”	80.75”

4. See Drawing #FL 3045 or Design Pressure Rating.


Wendell W. Haney, P.E.
PE # 54158
November 14, 2006

Supporting Documents

A Drawing

1. Drawing No. FL- 3045 titled "Opaque Fiberglass Single Door with Sidelite", "Impact", prepared by R W Building Consultants, Inc. (Florida Board of Professional Engineers Certificate of Authorization No. 9813), signed and sealed by Wendell W. Haney, P.E.

B Tests

1. Testing per TAS 201-94, TAS 202-94 and TAS 203-94 as performed by Testing Evaluation Laboratories and reported in test report number TEL 06-1031-1, dated November 8, 2006, signed and sealed by Wendell W. Haney, P.E.
2. Testing per TAS 201-94, TAS 202-94 and TAS 203-94 as performed by Testing Evaluation Laboratories and reported in test report number TEL 06-1031-4, dated October 31, 2006, signed and sealed by Wendell W. Haney, P.E.
3. Plastics testing (Fiberglass Skins) in accordance with the "High Velocity Hurricane Zone" substantiated by Issuance of Miami-Dade Notice of Acceptance 06-0406.11, expiring January 18, 2012.
4. Test report on "Standard Test Method for Surface Burning Characteristics of Building materials", per ASTM E84-00a (ASTM E84-00a is equivalent to ASTM E84-96) for flame spread and smoke development of Therma-Tru Corporation Insulated Steel Door Panel, conducted by Omega Point Laboratories, Test Report No. 15427-107362, dated August 28, 2000.
- 4a. Foam plastics testing per ASTM D1929-96(2000)e01, "Standard Test Method for Determining Ignition Temperature of Plastics", as performed by Architectural Testing Inc. and reported in test report number 67508.01-106-18, dated August 30, 2006, signed by Joseph A. Reed, P.E.
5. Plastics testing (Lite Frames) in accordance with the "High Velocity Hurricane Zone" substantiated by Issuance of Miami-Dade Notice of Acceptance 01-1120.08, expiring January 18, 2007.

C Calculations

1. Product Anchoring is in accordance with manufacturer's published recommendations as substantiated by tested specimens reported in test report number TEL 06-1031-1 and TEL 06-1031-4
2. Buck anchor analysis for loading conditions, prepared, signed and sealed by Wendell W. Haney, P.E.
3. Glass Load Resistance Report ASTM E1300-02 prepared by Wendell W. Haney, P.E.

D Other

Certificate of Participation issued by National Accreditation & Management Institute, Inc., certifying that Therma-Tru Corporation is manufacturing products within a quality assurance program.


Wendell W. Haney, P.E.

PE # 54158

November 14, 2006