


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006663
DATE: 08/04/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: T-052-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	Series "6-0 x 8-0 Fiberglass French Door" Fiberglass Side Hinge In-Swing Door Configuration: XX Glazing: IG-1/8" Tempered Glass Frame: W-1886mm(74.25") H-2489mm(98") Panel: W-914mm(36") H-2419mm(95.25") STP: Pos+2880Pa(60.15psf) Neg-2880Pa(60.15psf)

SPECIFICATION	PRODUCT RATING
AAMA/WDMA 101/LS.2/NAFS-02 AAMA/NWWDA 101/LS.2-97	HGD-LC40 1886 x 2489 (74 x 98) FER-Passed

Product Tested By: Architectural Testing, Inc.
Report No: 63827.01-602-47 (Structural/FER)
Expiration Date: April 30, 2010

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659