

NOTICE OF PRODUCT CERTIFICATION

Company: Therma-Tru Corporation
 108 Mutzfeld Road
 Butler, IN 46721

Certification No.: NI005312-R2
Certification Date: 10/15/2003
Expiration Date: 12/31/2009
Revision Date: 11/30/2007

Product: Traditions/Construction Series Wood Edge Opaque Steel Door Inswing/Outswing w/ and w/o Sidelites
Specifications Tested To: ASTM E330/E331/PA201/202/203

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Opaque	3'0" x 6'8"	+67/-67	Yes	ETC-01-741-10622.0(05/01/01)/L-2110
X Single	O/S	Opaque	3'0" x 6'8"	+67/-67	Yes	ETC-01-741-10622.0(05/01/01)/L-2110
XX Double	I/S	Opaque	6'0" x 6'8"	+40/-40	Yes	ETC-01-741-10622.0(05/01/01)/L-2110 Standard Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 6'8"	+40/-40	Yes	ETC-01-741-10622.0(05/01/01)/L-2110 Standard Aluminum Astragal
XX Double	I/S	Opaque	6'0" x 6'8"	+60/-60	Yes	ETC-01-741-10622.0(05/01/01)/L-2110 Coastal Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 6'8"	+60/-60	Yes	ETC-01-741-10622.0(05/01/01)/L-2110 Coastal Aluminum Astragal
OXO/OX/XO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	5'4" x 6'8"	+60/-60	Door-Yes Sidelites-No	ETC-01-741-11004.0(07/09/01)/L-2147
OXO/OX/XO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	5'4" x 6'8"	+60/-60	Door-Yes Sidelites-No	ETC-01-741-11004.0(07/09/01)/L-2147
OXXO Double w/Sidelites	I/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+40/-40	Doors-Yes Sidelites-No	ETC-01-741-11004.0(07/09/01)/L-2147 Standard Aluminum Astragal
OXXO Double w/Sidelites	O/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+40/-40	Doors-Yes Sidelites-No	ETC-01-741-11004.0(07/09/01)/L-2147 Standard Aluminum Astragal
OXXO Double w/Sidelites	I/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+60/-60	Doors-Yes Sidelites-No	ETC-01-741-11004.0(07/09/01)/L-2147 Coastal Aluminum Astragal
OXXO Double w/Sidelites	O/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+60/-60	Doors-Yes Sidelites-No	ETC-01-741-11004.0(07/09/01)/L-2147 Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./11870 Merchants Walk, Suite 202/Newport News, VA 23606
Tel-757.594.8658/Fax-757.594.8659

NAMI AUTHORIZED SIGNATURE: _____

