

NOTICE OF PRODUCT CERTIFICATION

Company: Therma-Tru Corporation
 108 Mutzfeld Road
 Butler, IN 46721

Certification No.: NI005327-R1
Certification Date: 10/15/2003
Expiration Date: 12/31/2009
Revision Date: 06/29/2007


Product: FiberClassic/Smooth Star Glazed Fiberglass Door Inswing/Outswing w/ and w/o Sidelites
Specifications Tested To: ASTM E330/E331/TAS202

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Glazed	3'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F
X Single	O/S	Glazed	3'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F
XX Double	I/S	Glazed	6'0" x 8'0"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-257F Standard Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 8'0"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-257F Standard Aluminum Astragal
XX Double	I/S	Glazed	6'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F Coastal Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F Coastal Aluminum Astragal
OXO/OX/XO Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F
OXO/OX/XO Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F
OXXO Double w/Sidelites	I/S	Glazed Doors Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F Standard Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Doors Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F Standard Aluminum Astragal
OXXO Double w/Sidelites	I/S	Glazed Doors Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2173/TTF-257F Coastal Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Doors Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2173/TTF-257F Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./11870 Merchants Walk, Suite 202/Newport News, VA 23606
Tel-757.594.8658/Fax-757.594.8659

NAMI AUTHORIZED SIGNATURE: _____



NOTICE OF PRODUCT CERTIFICATION

Company: Therma-Tru Corporation
 108 Mutzfeld Road
 Butler, IN 46721

Certification No.: NI005329-R1
Certification Date: 10/15/2003
Expiration Date: 12/31/2009
Revision Date: 06/29/2007

Product: Fiberclassic Opaque Fiberglass Door Inswing/Outswing w/ and w/o Sidelites
 Specifications Tested To: ASTM E330/E331/TAS202

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Opaque	3'0" x 8'0"	+67/-67	No	ETC-01-741-10703.0/L-2097/TTF-253F
X Single	O/S	Opaque	3'0" x 8'0"	+67/-67	No	ETC-01-741-10703.0/L-2097/TTF-254F
XX Double	I/S	Opaque	6'0" x 8'0"	+40/-40	No	ETC-01-741-10703.0/L-2097/TTF-253F Standard Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 8'0"	+40/-40	No	ETC-01-741-10703.0/L-2097/TTF-254F Standard Aluminum Astragal
XX Double	I/S	Opaque	6'0" x 8'0"	+47/-47	No	ETC-01-741-10703.0/L-2097/TTF-253F Coastal Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 8'0"	+47/-47	No	ETC-01-741-10703.0/L-2097/TTF-254F Coastal Aluminum Astragal
O XO/OX/XO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-253F
O XO/OX/XO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-254F
O X XO Double w/Sidelites	I/S	Opaque Doors Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-253F Standard Aluminum Astragal
O X XO Double w/Sidelites	O/S	Opaque Doors Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-254F Standard Aluminum Astragal
O X XO Double w/Sidelites	I/S	Opaque Doors Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2173/TTF-253F Coastal Aluminum Astragal
O X XO Double w/Sidelites	O/S	Opaque Doors Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2173/TTF-254F Coastal Aluminum Astragal

**National Accreditation & Management Institute, Inc./11870 Merchants Walk, Suite 202/Newport News, VA 23606
 Tel-757.594.8658/Fax-757.594.8659**

NAMI AUTHORIZED SIGNATURE: _____



NOTICE OF PRODUCT CERTIFICATION

Company: Therma-Tru Corporation
 108 Mutzfeld Road
 Butler, IN 46721

Certification No.: NI005330-R1
Certification Date: 10/15/2003
Expiration Date: 12/31/2009
Revision Date: 06/29/2007


Product: FiberClassic/Smooth Star Glazed Fiberglass Door Inswing/Outswing w/ and w/o Sidelites
 Specifications Tested To: ASTM E330/E331/TAS202

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Glazed	3'0" x 6'8"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-256F
X Single	O/S	Glazed	3'0" x 6'8"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-255F
XX Double	I/S	Glazed	6'0" x 6'8"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-256F Standard Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 6'8"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-255F Standard Aluminum Astragal
XX Double	I/S	Glazed	6'0" x 6'8"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-256F Coastal Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 6'8"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-255F Coastal Aluminum Astragal
OXO/OX/XO Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	5'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-256F
OXO/OX/XO Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	5'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-255F
OXXO Double w/Sidelites	I/S	Glazed Doors Glazed Sidelites	8'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-256F Standard Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Doors Glazed Sidelites	8'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-255F Standard Aluminum Astragal
OXXO Double w/Sidelites	I/S	Glazed Doors Glazed Sidelites	8'4" x 6'8"	+47/-47	No	ETC-01-741-11008.0/L-2151/TTF-256F Coastal Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Doors Glazed Sidelites	8'4" x 6'8"	+47/-47	No	ETC-01-741-11008.0/L-2151/TTF-255F Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./11870 Merchants Walk, Suite 202/Newport News, VA 23606
Tel-757.594.8658/Fax-757.594.8659

NAMI AUTHORIZED SIGNATURE: _____



NOTICE OF PRODUCT CERTIFICATION

Company: Therma-Tru Corporation
 108 Mutzfeld Road
 Butler, IN 46721

Certification No.: NI005331-R1
Certification Date: 10/15/2003
Expiration Date: 12/31/2009
Revision Date: 06/29/2007

Product: FiberClassic/Smooth Star Opaque Fiberglass Door Inswing/Outswing w/ and w/o Sidelites
Specifications Tested To: ASTM E330/E331/TAS202

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Opaque	3'0" x 6'8"	+67/-67	No	ETC-01-741-10702.0/L-2096/TTF252F
X Single	O/S	Opaque	3'0" x 6'8"	+67/-67	No	ETC-01-741-10702.0/L-2096/TTF251F
XX Double	I/S	Opaque	6'0" x 6'8"	+40/-40	No	ETC-01-741-10702.0/L-2096/TTF252F Standard Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 6'8"	+40/-40	No	ETC-01-741-10702.0/L-2096/TTF251F Standard Aluminum Astragal
XX Double	I/S	Opaque	6'0" x 6'8"	+55/-55	No	ETC-01-741-11008.0/L-2151/TTF252F Coastal Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 6'8"	+55/-55	No	ETC-01-741-11008.0/L-2151/TTF251F Coastal Aluminum Astragal
OXO/OX/XO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	5'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-252F
OXO/OX/XO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	5'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-251F
OXXO Double w/Sidelites	I/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-252F Standard Aluminum Astragal
OXXO Double w/Sidelites	O/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-251F Standard Aluminum Astragal
OXXO Double w/Sidelites	I/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+55/-55	No	ETC-01-741-11008.0/L-2151/TTF-252F Coastal Aluminum Astragal
OXXO Double w/Sidelites	O/S	Opaque Doors Glazed Sidelites	8'4" x 6'8"	+55/-55	No	ETC-01-741-11008.0/L-2151/TTF-251F Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./11870 Merchants Walk, Suite 202/Newport News, VA 23606
Tel-757.594.8658/Fax-757.594.8659

NAMI AUTHORIZED SIGNATURE: _____

