



LISTING INFORMATION OF Therma Tru 20 Min Hollow Metal Polyurethane Core Embossed
Fire Door NP Model 20HMPCEFDNP

SPEC ID: 20336

Therma Tru Corporation
1750 Indian Wood Circle
Maumee, OH 43537

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Hollow Metal Type (24 & 25 gauge)(Steel-Faced)(Foam-Filled), Swinging Flush or Embossed Design Fire Door for installation in single swing 20 minute locations without hose stream.

Limitations

Unit, Mortise, or Cylindrical Latches with up to a 5" backset/Deadbolts

For installation in steel or wood frames.

Maximum Size

Singles - 3'0" wide x 7'0" high OR 3'6" wide x 6'8" high

All assemblies are identified by a label or marking bearing the wording, "Listed (Product)", a time interval, temperature rise (if applicable), a serial number and the WHI Certification Mark.

(Unless otherwise specified, all Fire Doors have a nominal thickness of 1-3/4")

<u>Attribute</u>	<u>Value</u>
CSI Code	08 11 00 Metal Doors and Frames
CSI Code	08 11 13 Hollow Metal Doors and Frames
Fire Resistance	20 Min w/out Hose Stream NP
Listed or Inspected	LISTED
Report Number	J20001268-231, 3032869-1, 3042535-1, 3145208MID-003a, 3179434MID-004
Criteria	NFPA 252 (2008)
Criteria	UL 10(b) Revision 1 (2009)
Intertek Services	Certification
Listing Section	CATEGORY A - DOORS - NO ADDITIONAL EDGE-SEALING SYSTEM REQUIRED
Test Original Issue Date	03/21/2000, 10/28/2002, /05/28/2003, 03/06/2008, 05/14/2009
Verification Testing	YES
Verification Test Type	FTIR